

Chiller - BR 250 Y LN Low noise

Technical data (218224-219174-220071)

Min leaving water/glycol temperature	°C	-10
Max entering water temperature	°C	15
STD ambient air temperature	°C	35
Hydraulic pump	n°	1
Water flow	m³/h	from 20 to 40
Tot. Static pressure	kPa	from 355 to 292
Max pressure	Bar	6
Storage tank	litres	660
Water connections	mm	100 (4")

OPERATION

	STANDARD	(ICE RINKS)
El. Connections	terminals M 10	M 10
Max abs. Power	kW 108	77
Max abs. current MRA	A 195	143
Starting current LRA	A 377	377
El. Supply	V/Ph/Hz 400/3/50+PE	400/3/50+PE

Sound pressure level 5 m	db (A)	59*
Transport weight	kg	3.260
Operation weight	kg	4.060
Transport Length	mm	4.400
Transport Width	mm	2.450
Transport Height	mm	2.400

Optional

Connection cable 3 x 1 x 120 mm² + 1 x 70 mm²
Flexible hoses complete with quick connect coupling 4" / Ø 100 mm



Emissione: 09/21

BRENTA RENT S.r.l. Sede Legale: Via Alsazia, 3 sc. A/10 - 35127 PADOVA Cap. sociale € 12.000,00
Sede Operativa ed amministrativa: **Via dell'Industria, 17 - 35020 ARZERGRANDE (PD)**
e.mail: brenta@brentarent.it www.brentarent.it PEC: brentarent@pec.it
tel. +39 049 5800034 fax. +39 049 9724623 cell. +39 347 0554982
P.I./C.F.: 03667010288 N° REA: PD 327292

AZIENDA CON
SISTEMA DI GESTIONE QUALITA'
CERTIFICATO DA DNV
ISO 9001



Il freddo a noleggio

** Free field sound pressure level taken at 1 m from the unit and 1,5 m from its base, compressors side and full operating unit without hydraulic kit. The sound pressure level may change according to the various installation and has a +/- 3 dB(A) tolerance according to ISO 3744.*

Emissione: 09/21

BRENTA RENT S.r.l. Sede Legale: Via Alsazia, 3 sc. A/10 - 35127 PADOVA Cap. sociale € 12.000,00
Sede Operativa ed amministrativa: **Via dell'Industria, 17 - 35020 ARZERGRANDE (PD)**
e.mail: brenta@brentarent.it www.brentarent.it PEC: brentarent@pec.it
tel. +39 049 5800034 fax. +39 049 9724623 cell. +39 347 0554982
P.I./C.F.: 03667010288 N° REA: PD 327292

AZIENDA CON
SISTEMA DI GESTIONE QUALITA'
CERTIFICATO DA DNV
ISO 9001