

# Chiller – BRV 30 compressor variable speed

### Technical data (221052-222015-222063)

Min leaving water/glycol temperature	°C	-5
Max water temperature	°C	in/out 15/10
STD ambient air temperature	°C	+35
<b>INVERTER hydraulic pump</b>	n°	1
Water flow	m <sup>3</sup> /h	from 1,8 to 4,8
Tot. Static pressure	kPa	from 280 to 200
Max pressure	Bar	6
Storage tank	litres	100
Water connections	mm	50 (2")
<b>Operation</b>		<b>STANDARD</b>
El. Connections	cable	4 x 6 mm <sup>2</sup>
Mx abs. Power	kW	9.0
Max abs. current MRA	A	22.0
Starting current LRA	A	20.0
El. Supply	V/Ph/Hz	400/3/50+N+PE
Sound pressure level @5 m	db (A)	54*
Transport weight	kg	420
Operation weight	kg	525
Transport Length	mm	2.150
Transport Width	mm	1.000
Transport Height	mm	1.650

### Optional

Connection cable 4 x 6 mm<sup>2</sup>

Flexible hoses complete with quick connect coupling 2" / Ø 50 mm



\*Free field sound pressure level taken at 1 m from the unit and 1,5 m from its base, compressors side and full operating unit without hydraulic kit. The sound pressure level may change according to the various installation and has a +/- 3 dB(A) tolerance according to ISO 3744.

Emissione: 03/2024

**BRENTA RENT S.r.l.** Sede Legale: Via Alsazia, 3 sc. A/10 - 35127 PADOVA Cap. sociale € 12.000,00  
Sede Operativa ed amministrativa: **Via dell'Industria, 17 - 35020 ARZERGRANDE (PD)**  
e.mail: [brenta@brentarent.it](mailto:brenta@brentarent.it) [www.brentarent.it](http://www.brentarent.it) PEC: [brentarent@pec.it](mailto:brentarent@pec.it)  
tel. +39 049 5800034  
P.I./C.F.: 03667010288 N° REA: PD 327292

AZIENDA CON  
SISTEMA DI GESTIONE QUALITÀ  
CERTIFICATO DA DNV  
ISO 9001