

# Chiller – BR 65 Y

## Technical data (218014-218107)

Min leaving water/glycol temperature	°C	-10
Max entering water temperature	°C	15
STD ambient air temperature	°C	35
<b>Hydraulic pump</b>	n°	1
Water flow	m <sup>3</sup> /h	from 5.5 to 13.5
Tot. Static pressure	kPa	from 330 to 180
Max pressure	Bar	6
Storage tank	litres	200
Water connections	mm	50 (2")

<b>Operation</b>		<b>STANDARD</b>	<b>ICE RINKS</b>
El. Connections	cable	4G16 mm <sup>2</sup>	4G16 mm <sup>2</sup>
Max abs. Power	kW	24,3	17,3
Max abs. current MRA	A	52	33
Starting current LRA	A	143,5	140
El. Supply	V/Ph/Hz	400/3/50+PE	
Sound pressure level @5 m	dB(A)	53*	
Transport weight	kg	1.060	
Operation weight	kg	1.320	
Transport Length	mm	3.300	
Transport Width	mm	1.250	
Transport Height	mm	2.400	

## Optional

Connection cable 4 x 16 mm<sup>2</sup>

Flexible hoses complete with quick connect coupling 2" / 50 mm



\* Free field sound pressure level taken at 1 m from the unit and 1,5 m from its base, compressors side and full operating unit without hydraulic kit. The sound pressure level may change according to the various installation and has a +/- 3 dB(A) tolerance according to ISO 3744.

Emissione: 09/21

**BRENTA RENT S.r.l.** Sede Legale: Via Alsazia, 3 sc. A/10 - 35127 PADOVA Cap. sociale € 12.000,00  
Sede Operativa ed amministrativa: **Via dell'Industria, 17 - 35020 ARZERGRANDE (PD)**  
e.mail: [brenta@brentarent.it](mailto:brenta@brentarent.it) [www.brentarent.it](http://www.brentarent.it) PEC: [brentarent@pec.it](mailto:brentarent@pec.it)  
tel. +39 049 5800034 fax. +39 049 9724623 cell. +39 347 0554982  
P.I./C.F.: 03667010288 N° REA: PD 327292

AZIENDA CON  
SISTEMA DI GESTIONE QUALITA'  
CERTIFICATO DA DNV  
ISO 9001